



KERALA WATER AUTHORITY
QUALITY CONTROL SUB DISTRICT LABORATORY
PULIKKEEZHU, THIRUVALLA
 Telephone No. 0469 2999833, Email : kwaqcslplkz@gmail.com
TEST REPORT

801/PLKZ/02/2025(NR)

Date: 21.02.2025

Customer Name & Address

**CLUNY SCHOOL
 CHANGANACHERRY P.O
 KOTTAYAM (DIST)
 KERALA**

1. Date of Payment Received	20.02.2025
2. Date of Sample Received	20.02.2025
3. Time of Sampling	1.27 PM
4. Sampling done by	Customer
5. Sample Code	2025/QCSDL/PLKZ/P 803
6. Source of Sample	WELL
7. Sample Quantity	2 LITRE
8. Sampling Method	Not Applicable
9. Test performing dates	From: 20.02.2025 to 20.02.2025

Sl. No	Characteristics	Unit	Test Method	Maximum acceptable limits as per IS 10500-2012	Limit of Quantification (LOQ)	Result
1	Colour	HU	APHA 24 th edition 2120 Colour method B	5	1HU	1
2	Odour		IS 3025 (part 5) -2018		Qualitative	Agreeable
3	Taste		IS 3025 (part 8) -1984		Qualitative	NT
4	Turbidity	(NTU)	IS 3025(part10)-1984	1	0.5 NTU	< 0.5
5	pH at 25°C		IS 3025(part 11)-2022	6.5-8.5	2	6.04
6	Total Alkalinity (as CaCO ₃)	(mg/L)	IS 3025(part 23)-1986	200	1mg/L	4.04
7	Total Dissolved Solids	(mg/L)	IS 3025(part16)-1984	500	5mg/L	7.67
8	Total Hardness (as CaCO ₃)	(mg/L)	IS 3025(part21)-2009	200	1mg/L	2
9	Calcium(as Ca)	(mg/L)	IS 3025(part40)-1991	75	1mg/L	< 1
10	Magnesium (as Mg)	(mg/L)	APHA 24 th edition 3500 – Mg Method B	30	1mg/L	< 1
11	Chloride(as Cl)	(mg/L)	IS 3025(part32)-1988	250	1mg/L	3.94
12	Electrical Conductivity at 25°C	(microS/cm)	IS 3025(part14)-2013		1µS/cm	11.97
13	Acidity	(mg/L)	IS 3025(part22)-1986		0.5mg/L	6.06
14	Sulphate (as SO ₄)	(mg/L)	IS 3025(part24)-1986	200	1 mg/L	< 1
15	Fluoride (as F)	(mg/L)	APHA 24 th edition- F ⁻ D	1	0.1 mg/L	< 0.1
16	Iron (as Fe)	(mg/L)	IS 3025(part53)-2003	1	0.1mg/L	< 0.1
17	Nitrate (as NO ₃)	(mg/L)	APHA 24 th edition 4500 – NO ₃ ⁻ B	45	2mg/L	< 2

Remarks:-

NT:- Not Tested

NB:-The results stated above related only to the sample(s) submitted for testing. This test Certificate shall not be reproduced except in full without the written approval of the Laboratory.

DEPUTY QUALITY MANAGER
QUALITY CONTROL SUB DISTRICT LABORATORY
KERALA WATER AUTHORITY
PULIKKEEZHU, THIRUVALLA

Authorized By

Name: Suji S

Deputy Quality Manager

** End of Report **

KWA PLKZ R1 NA

Issue No:02

Issue Date: 01.12.2021

Rev. No:06

Rev. Date: 16.12.2024



KERALA WATER AUTHORITY
QUALITY CONTROL SUB DISTRICT LABORATORY
PULIKKEEZHU, THIRUVALLA

Telephone No. 0469 2999833, E.mail :kwaqcsdlplkz@gmail.com

TEST REPORT

Report No:801 /PLKZ/02/2025(MB)		Date: 21.02.2025
Customer Name & Address CLUNY SCHOOL CHANGANACHERRY P.O KOTTAYAM (DIST) KERALA	1.Date of Payment Received	20.02.2025
	2. Date of Sample Received	20.02.2025
	3. Time of Sampling	1.27 PM
	4. Sampling done by	Customer
	5. Sample Code	2025/QCSDL/PLKZ/P 803
	6. Source of Sample	WELL
	7. Sample Quantity	200 ml
	8.Sampling Method	Not Applicable
	9.Test performing dates	From : 20.02.2025 to 21 .02.2025

BACTERIOLOGICAL ANALYSIS

Sl. No	Parameters	Acceptable limits as per IS 10500 - 2012	Test Method	Result
1	Total Coliforms	Shall not be detected/100 ml	IS 15185 : 2021	ABSENT
2	E.coli	Shall not be detected/100 ml	IS 15185 : 2021	ABSENT

Remarks:-

NB:-The results stated above related only to the sample(s)submitted for testing. This test Certificate shall not be reproduced except in full without the written approval of the Laboratory.

QUALITY CONTROL SUB DISTRICT LAB.
KERALA WATER AUTHORITY
PULIKKEEZHU, THIRUVALLA

Verified By

Name :Jini S Thankappan
Bacteriologist

Dr. Jocelyn
Manager
CLUNY SCHOOL
Changanacherry-686 101

** End of Report **



Jini S
Principal
CLUNY SCHOOL
Changanacherry
Kottayam Dist.
KERALA-686 101

KWA PLKZ R4 NA Issue No:02

Issue Date: 30.06.2021

Rev. No:06

Rev. Date: 16.12.2024

Changanassery



Municipality

Phone: 0481-2420044,
2420897, 2421311
GST No: 32AAAGM0032R2ZF

Kottayam Dist
Pincode - 686101

Mail & Web: secretarychsry@gmail.com, ChanganacherryMunicipality.lsgkerala.gov.in

H6 - 751640/25

Date: 29/03/2025

SANITARY CERTIFICATE

Cluny Senior Secondary School, Changanassery was inspected by the Public Health Inspector on 07/03/2025 and in general found that the sanitary conditions there were satisfactory.




Clean City Manager
Changanassery Municipality

MANOJ M
CLEAN CITY MANAGER
CHANGANACHERRY MUNICIPALITY
PEN : G66678

Dr. Jocelyn

SS

Manager
CLUNY SCHOOL
Changanacherry-686 101



Jiji J

Principal
CLUNY SCHOOL
Changanacherry
Kottayam Dist.
KERALA- 686 101